

NOTE: 24"X36" SLAB OPENING FOR NEENAH R-3067-V CASTING AND TYPE GRATE.

OTHER POTENTIALS AVAILABLE FOR THE CASTING DEPENDING UPON CIRCUMSTANCES AND SUBJECT TO CITY APPROVAL:

- NEENAH R-2561-A BEEHIVE GRATE & CASTING
- NEENAH R-2573 CONCAVE GRATE & CASTING
- NEENAH R-2577 CONVEX GRATE & CASTING
- NEENAH R-3250-1 GRATE & CASTING
- NEENAH R-3290-A FOR CROSS GUTTERS
- NEENAH R-3501-TR & TL FOR SURMOUNTABLE CURB
- NEENAH R-4342 WITH CONCRETE MNDOT FRAME PLATE #4143E

DIMENSION FROM BACK OF CURB TO CENTER OF PIPE.

- 4' DIA. M.H.-9" IN FROM BACK OF CURB
- 6' DIA. M.H.-3" BEHIND BACK OF CURB
- 8' DIA. M.H.-15" BEHIND BACK OF CURB

VARIABLE THICKNESS HDPE ADJUSTING RINGS AS REQUIRED. MINIMUM OF 4" ADJUSTMENT AND MAXIMUM OF 12" ADJUSTMENT. USE LARGER ADJUSTMENT RINGS TO MINIMIZE THE NUMBER OF JOINTS. INCLUDE MIN. (1)-2" RING IMMEDIATELY UNDER THE CASTING. THERE CAN BE NO MORE THAN 3" OF OFFSET IN ANY DIRECTION IN THE ADJUSTING RING PLACEMENT. USE TAPERED RINGS TO MATCH CASTING TO STREET GRADE. APPLY BUTYL SEALANT BETWEEN THE FIRST RING AND THE STRUCTURE AND BETWEEN THE UPPER RING AND THE CASTING. DON'T APPLY SEALANT TO THE MIDDLE JOINTS. WRAP THE OUTSIDE OF THE RINGS WITH A NON-WOVEN GEOTEXTILE FABRIC.

RAMNEK OR SIMILAR GASKET TYPE MATERIAL TO BE PLACED BETWEEN SLAB AND TOP OF MANHOLE SECTION.

ALL MANHOLE JOINTS TO HAVE RUBBER GASKETS

PRECAST CONCRETE MANHOLE SECTION.

MANHOLE STEPS NEENAH R1981J PLASTIC COATED OR APPROVED EQUAL, 16" O.C. USE PRECAST SECTIONS WHENEVER POSSIBLE.

USE MIN. 4' DIAMETER MANHOLE SECTIONS FOR PIPE SIZES UP TO 36" DIAMETER.

DOGHOUSES SHALL BE GROUTED ON BOTH THE OUTSIDE AND INSIDE.

BOTH BASE SLAB AND TOP SLAB VARIES IN THICKNESS, (6" MINIMUM-12" MAXIMUM) DEPENDING UPON STRUCTURE DIAMETER AND DEPTH. FOLLOW MANUFACTURES SPECIFICATIONS.

GROUT INVERT BOTTOM TO 1/2 DIA. OF PIPE.

NEENAH R-2561-A BEEHIVE GRATE & CASTING
NEENAH R-2573 CONCAVE GRATE & CASTING
NEENAH R-2577 CONVEX GRATE & CASTING
NEENAH R-3250-1 GRATE & CASTING
NEENAH R-3290-A FOR CROSS GUTTERS
NEENAH R-3501-TR & TL FOR SURMOUNTABLE
CURB
NEENAH R-4342 WITH CONCRETE MNDOT FRAME
PLATE #4143E

4' DIA. M.H.-9" IN FROM BACK OF CURB
6' DIA. M.H.-3" BEHIND BACK OF CURB
8' DIA. M.H.-15" BEHIND BACK OF CURB

VARIABLE THICKNESS HDPE ADJUSTING RINGS AS REQUIRED. MINIMUM OF 4" ADJUSTMENT AND MAXIMUM OF 12" ADJUSTMENT. USE LARGER ADJUSTMENT RINGS TO MINIMIZE THE NUMBER OF JOINTS. INCLUDE MIN. (1)-2" RING IMMEDIATELY UNDER THE CASTING. THERE CAN BE NO MORE THAN 3" OF OFFSET IN ANY DIRECTION IN THE ADJUSTING RING PLACEMENT. USE TAPERED RINGS TO MATCH CASTING TO STREET GRADE. APPLY BUTYL SEALANT BETWEEN THE FIRST RING AND THE STRUCTURE AND BETWEEN THE UPPER RING AND THE CASTING. DON'T APPLY SEALANT TO THE MIDDLE JOINTS. WRAP THE OUTSIDE OF THE RINGS WITH A NON-WOVEN GEOTEXTILE FABRIC.

RAMNEK OR SIMILAR GASKET TYPE
MATERIAL TO BE PLACED BETWEEN
SLAB AND TOP OF MANHOLE SECTION.

ALL MANHOLE JOINTS TO HAVE RUBBER GASKETS

-PRECAST CONCRETE MANHOLE SECTION.

MANHOLE STEPS NEENAH R1981J PLASTIC
COATED OR APPROVED EQUAL, 16" O.C.

USE PRECAST SECTIONS WHENEVER POSSIBLE.

USE MIN. 4' DIAMETER MANHOLE SECTIONS
FOR PIPE SIZES UP TO 36" DIAMETER.

DOGHOUSES SHALL BE GROUTED ON BOTH
THE OUTSIDE AND INSIDE.

BOTH BASE SLAB AND TOP SLAB VARIES IN THICKNESS, (6"MINIMUM-12"MAXIMUM) DEPENDING UPON STRUCTURE DIAMETER AND DEPTH. FOLLOW MANUFACTURES SPECIFICATIONS.

-GROUT INVERT BOTTOM TO 1/2 DIA. OF PIPE.



STANDARD DETAILS
PRECAST STORM SEWER CATCH BASIN MANHOLE
WITH REINFORCED CONCRETE TOP SLAB
CITY OF PLYMOUTH

PUBLISHED
1-19

CITY PL. NO.
ST-6
REVISED 1-18