

THE CITY OF PLYMOUTH REQUIRES THAT THE CONTRACTOR'S NAME AND THE FOLLOWING NOTES AND STATEMENTS BE PLACED ON EACH WATERMAIN OR SANITARY SEWER RECORD PLAN SHEET.

RECORD PLAN NOTES:

1. ALL HYDRANT BENCHMARKS ARE TOP NUT OF HYDRANT.
2. DISTANCES, ELEVATIONS AND TIES ARE BASED ON FIELD MEASUREMENTS TAKEN AFTER CONSTRUCTION. WYE LOCATIONS SUPPLIED BY CONTRACTORS.
3. ALL TIES AND DISTANCES ARE TO THE CENTER OF SURFACE STRUCTURES.
4. ALL HYDRANTS AND HYDRANT GATE VALVES ARE RETAINED AND TIED BACK TO THE WATERMAIN TEE BY MEANS OF APPROVED MEGALUGS UNLESS OTHERWISE NOTED.
5. ALL SEWER SERVICES ARE LOCATED 3 FEET DOWNSTREAM OF WATER SERVICES IF SEWER AND WATER ARE IN THE SAME TRENCH.
6. ALL WATER SERVICES ARE 1 INCH H.D.P.E. AND ALL SEWER SERVICES ARE 4 INCH P.V.C. UNLESS OTHERWISE SPECIFIED.
7. ALL SEWER AND WATER SERVICES ARE EXTENDED 10 FEET BEYOND THE PROPERTY LINE UNLESS OTHERWISE NOTED.

RECORD PLAN COMPLETED BY: _____

DATE: _____



STANDARD DETAILS
REQUIRED NOTES ON WATERMAIN
AND SANITARY SEWER RECORD PLAN
CITY OF PLYMOUTH

PUBLISHED
3-23

CITY PL. NO.
DWG-3
REVISED 3-11